

2023 05 29

2023 05 29

				2023 5 29												
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
	mg/L	mg/L		NTU			pH	mg/L	mg/L	mg/L	CFU/ml	MPN/100ml	MPN/L	MPN/100ml	mg/L	mg/L
2305291()	-	-	15	1.38	0		7.27	1.60	-	0.278	/	/	/	-	0.064	0.143
2305292()	0.16	0.32	5	0.178	0		7.30	1.12	0.02	-	/	/	-	/	0.02	0.014
GB3838-2002							6.9	6		1.0			10000		0.3	0.1
GB/T5749-2022	0.1 0.8	0.3 2	15	1			6.5 8.5	3	0.5		100				0.3	0.1
	(GB5750-2006)					1 2										