

2023 09 03

2023 09 03

				2023 9 03												
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
				NTU			pH		CFU/ml	MPN/100ml	MPN/L	MPN/100ml	mg/L	mg/L	mg/L	mg/L
2309031()	-	-	20	15.8	0		7.35	3.04	/	/	/	-	-	0.240	<0.02	0.022
2309032()	0.19	0.28	<5	0.187	0		7.30	1.20	/	/	-	/	0.02	<0.02	<0.02	0.02
GB3838-2002							6.9	6			10000			1.0	0.3	0.1
GB/T5749-2022	0.1 0.8	0.3 2		1			6.5 8.5	3	100				0.5		0.3	0.1
	(GB5750-2006)					1 2										